



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20120647, Building Permit - Commercial  
Address: 1041 NE SAM WALTON LN, Unit:B, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Final Electrical Inspection - Commercial</b>	John Borns	Not Ready	Wednesday, June 27, 2012

Corrective Action Required  
2 MISC

RTU ELECTRICAL FEEDER AND RECEPT SUBJECT TO APPROVAL WHEN ACCESS TO ROOF IS PROVIDED.

<b>Electrical Service Inspection - Commercial</b>	John Borns	Passed	Wednesday, June 27, 2012
---	------------	--------	--------------------------

**Comments: SERVICE RELEASE NOT REQUIRED. METER INSTALLED EARLIER BY KCP&L WITHOUT AUTHORIZATION.**