



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20120827, Building Permit - Commercial  
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Failed	Wednesday, June 27, 2012

Corrective Action Required  
1 MISC

COMPLETE ALL ELECTRICAL INSTALLATION AND TERMINATIONS; PLUG ALL UNUSED OPENINGS AT J.B.'s; CLOSE ALL BOXES

Corrective Action Required  
2 MISC

NEC 330.30: SECURE MC ELECTRICAL CABLE WITHIN 12" OF ENTRY TO BOXES EXCEPT FIXTURE WHIPS < 6" LONG

Corrective Action Required  
3 MISC

REMOVE TEMPORARY ELECTRICAL WIRING

Corrective Action Required  
4 MISC

AT STUDS ACTING IN TENSION SCREW FLANGE-TO-FLANGE CONNECTIONS AT BOTH FLANGES

Corrective Action Required  
5 MISC

UNLESS DRAWINGS INDICATE OTHERWISE, MINIMUM 2 SCREWS AT STUD WEB-TO-WEB CONNECTIONS

**Comments:**