



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20120721
Address: 1041 NE SAM WALTON LN, Unit:B, LEES SUMMIT, MO 64086
Inspected On: Thursday, June 28, 2012
Inspected By: John Borns
Expiration Date: 7/12/2012 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Thursday, June 28, 2012

Corrective Action Required:

1	MISC	NEC 408.4 ELECTRICAL PANEL SCHEDULE / LABELING OF ELECTRICAL CIRCUIT POSITIONS AT PANEL(S): EACH BREAKER POSITION MUST BE LABELED. MUST BE LEGIBLE; SPECIFIC. IF PANEL SCHEDULE IS USED NUMBER POSITIONS ON PANEL FRONT PER SCHEDULE. NO DITTO MARKS OR CONTINUATION SYMBOLS EXCEPT @ MULTIPLE POLE BREAKERS. LABEL UNUSED BREAKERS "SPARE"
---	------	---

Corrective Action Required:

2	MISC	ALUMINUM/GLASS STROEFONT MODIFICATIONS IN PROGRESS. ENSURE ALL GLAZING IS ETCHED "TEMPERED"
---	------	---

Corrective Action Required:

3	MISC	RESOLVE FIRE DEPARTMENT ISSUE(S)
---	------	----------------------------------

Corrective Action Required:

4	MISC	SEAL MOP SINK TO WALL AND FLOOR
---	------	---------------------------------

Comments: