



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20120827, Building Permit - Commercial  
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Partial	Thursday, June 28, 2012

Partial Correction  
4 MISC

AT STUDS ACTING IN TENSION SCREW FLANGE-TO-FLANGE  
CONNECTIONS AT BOTH FLANGES: OK TO COVER WHEN  
READY ALL CLOUD SOFFITS EXCEPT SE 4' AT SOUTH SERVERY  
WHERE FOUR TENSION STUDS ARE NOT SECURED TO  
STRUCTURE ABOVE

**Comments:**