



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110083, Building Permit - Commercial
Address: 621 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Passed	Friday, June 29, 2012
Partial Correction 1 MISC		PROGRESS INSPECTION OF LIGHT-GAUGE STEEL FRAMING	
In-wall Inspection	John Borns	Partial	Friday, June 29, 2012
Partial Correction 1 MISC		OK TO COVER WHEN READY WALL FRAMING & IN-WALL SYSTEMS @ INTERIOR & EXTERIOR WALLS AFTER: 1) VERTICAL DWV & WATER PIPING IS SECURED THROUGHOUT ITS HEIGHT 2) ELECTRICAL BOX STAND-OFFS ARE EXTENDED TO ENSURE SOLID BOXES	

Comments: