



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121287, Building Permit - Commercial
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - Commercial	John Borns	Partial	Monday, July 02, 2012

Partial Correction
1 MISC

OK TO COVER WHEN READY 4" PVC WATER PIPE FROM STA
0+10 TO 0+24.14 TO 0+124.14;

Comments: THRUST BLOCK TO BE INSTALLED AT 0+24.14 BEFORE COVERING.