



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20121287, Building Permit - Commercial  
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Water Service Inspection - Commerciall</b>	John Borns	Partial	Monday, July 02, 2012
Partial Correction 1 MISC		OK TO COVER WHEN READY 4" PVC WATER PIPE FROM STA 0+10 TO 0+24.14 TO 0+124.14;	
<b>Water Service Inspection - Commerciall</b>	John Borns	Partial	Monday, July 02, 2012
Partial Correction 1 MISC		OK TO COVER WHEN READY 4" PVC WATER PIPE FROM STA 0+10 TO 0+24.14 TO 0+124.14 TO 0+204.14	

**Comments: DO NOT COVER THRUST BLOCKS BEFORE THEY ARE INSPECTED AND DOCUMENTED.**