



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRRES20121444, Building Permit - Residential
Address: 713 NW BLACK TWIG LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------|----------|------------------------|
| Electrical Service Inspection - Residential | John Borns | Failed | Tuesday, July 03, 2012 |

Corrective Action Required

- | | | |
|---|------|---|
| 1 | MISC | ANIT-OXIDIZING COMPOUND REQUIRED AT TERMINATIONS OF ALUMINUM CONDUCTORS |
| 2 | MISC | NEC 110 - 26 (a) (b); IRC 3305.1: DEDICATED WORKING/CLEAR SPACE AT ELECTRICAL EQUIPMENT MUST BE WIDTH OF EQPMT OR 30" BY 36" DEEP |
| 3 | MISC | NEC 250; IRC E3510.1. SERVICE ENCLOSURES & EQUIPMENT MUST BE BONDED |

Comments: CALL TO REQUEST RE-INSPECTION WHEN READY