



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121491, Building Permit - Commercial
Address: 901 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Failed	Thursday, July 05, 2012

Corrective Action Required
1 MISC

NO MATERIAL OR ISSUES FOUND ON C.I. UNDER-SLAB DWV PIPING; HOWEVER, CONFIGURATION OF WORK IN PLACE VARIES FROM DRAWING. APPROVAL AWAITS SUBMISSION AND APPROVAL OF REVISED DRAWING.

Comments: IF COVER, AT RISK.