



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121287, Building Permit - Commercial
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Plumbing Inspection - Commercial	John Borns	Passed	Friday, July 06, 2012

Comments: INSTALLATION COMPLETE. LINE CHLORINE-TREATED AND FLUSHED TO CLEAR CONDITION. REMAINING BACKFILL TO BE COMPLETED PRESENTLY. RESTORATION OF SIDEWALK, LAWN IRRIGATION AND LANDSCAPING BY OTHERS. CLOSE PERMIT.