



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20120184, Building Permit - Commercial
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Monday, July 09, 2012
Partial Correction 1 MISC		ALL DESIGNATED SMOKE WALLS FOUND TO BE SCREWED AT 8"/12" PATTERN SIMILAR TO THAT AT DESIGNATED FIRE WALLS.	
Partial Correction 2 MISC		OK TO TAPE, MUD & FIRE SEAL FIRE-RATED WALLS AT FOLLOWING LOCATIONS: CORRIDOR 140 EAST WALL NORTH OF CC.4/1.5; 138 N WALL; 139 S&W WALLS;	
Partial Correction 3 MISC		OK TO COVER WHEN READY COMPONENTS OF TYPE "F" 2HR RATED WALL ASSEMBLY: 2ND FLR AHU EAST & SOUTH WALLS FRAMING + SHAFT LINER;	
Above Ceiling Inspection	John Borns	Passed	Monday, July 09, 2012
Partial Correction 1 MISC		OK TO COVER WHEN READY GWB CEILING FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: SOFFIT @ NURSE STATION 120; 141; 142; 146;	

Comments: