



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O. BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20114544, Building Permit - Commercial
Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Thursday, July 12, 2012
Partial Correction 1 MISC		OK TO COVER WHEN READY RATED ASSEMBLY COMPONENTS OF FREIGHT ELEVATOR SHAFT: LID COMPLETE INCLUDING FIRE CAULK; SHAFT @ 4TH & 5TH FLR COMPLETE INCLUDING FIRE CAULK; SHAFT @ 3RD FLR FRAMING, SHAFT LINER + TWO LAYERS 5/8" TYPE X GWB	
Partial Correction 2 MISC		CLOSURE AT 4TH FLR S.E. CORNER PER 2/A2.8: FRAMING + SHAFT LINER + 1ST & 2ND LAYERS OF 5/8" TYPE X GWB OK TO COVER WHEN READY CLOSURE AT 3RD FLR S.E. CORNER PER 2/A2.8: FRAMING, SHAFT LINER + 5/8" TYPE X GWB OK TO COVER WHEN READY	
Partial Correction 3 MISC		OK TO COVER WHEN READY COMPONENTS OF RATED ASSEMBLY AT UTILITY SHAFT: 4TH & 5TH FLOOR COMPLETE INCLUDING FIRE CAULK;	
Partial Correction 4 MISC		RATED WALL @ 3RD FLOOR ON (15) FROM (AA.8) TO (CC.4): FRAMING, SHAFT LINER + TWO LAYERS 5/8" TYPE X GWB OK TO TAPE, MUD & FIRE-SEAL	
Partial Correction 5 MISC		OK TO COVER WHEN READY TYPE "A" WALL RATED ASSEMBLY COMPONENTS AT LOCATIONS: SPACE 3F014 ALL WALLS BOTH FACES ONE LAYER 5/8" TYPE X GWB OK TO TAPE, MUD &	

FIRE-SEAL

Partial Correction
6 MISC

TEMPORARY CLOSURE @ ELEVATOR DOOR OPENINGS: #1
THIRD FLOOR RESTORED WITH FRAMING, LINER BOARD + TWO
LAYERS 5/8" TYPE X GWB OK TO COVER WHEN READY; #2
ELEVATOR DOOR @ FIRST FLOOR RESTORED WITH FRAMING,
LINER BOARD + ONE LAYER 5/8" TYPE X GWB

Partial Correction
7 MISC

UTILITY CHASE AT F/6 ON 3RD FLR: FRAMING + LINER BOARD +
TWO LAYERS 5/8" TYPE X GWB OK TO TAPE, MUD AND
FIRE-CAULK WHEN READY

Comments: