



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20110083, Building Permit - Commercial  
Address: 621 SW 3RD ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Commercial</b>	John Borns	Partial	Thursday, July 12, 2012

Partial Correction  
4 MISC

BUILDING STEEL GROUND JUMPER INSTALLED. 3/4" x 10'  
GROUND ROD + G.E.C. INSTALLED PER DRAWING. OK FOR  
INSTALLATION OF SERVICE CONDUCTORS AND FOR  
ACTIVATION OF HVAC SYSTEM FOR CONSTRUCTION COOLING.

Corrective Action Required  
5 MISC

FURTHER INSPECTION REQUIRED AS SERVICE EQUIPMENT  
INSTALLATION AND TERMINATIONS ARE COMPLETED.

**Comments:**