



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20116302, Building Permit - Commercial  
Address: 517 SW MARKET ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Final Building Inspection - Commercial</b>	John Borns	Failed	Thursday, July 12, 2012

Corrective Action Required  
1 MISC

COLUMN PIERS ARE HEAVILY HONEYCOMBED. PER 6/28/12 TELECON W/ LARRY STUCKER, HE WILL HAVE THEM FILLED & RUBBED.

**Comments:**