



LEE'S SUMMIT, MISSOURI FIRE DEPARTMENT LOSS REDUCTION PROGRAM



NOTIFICATIONS/CONTACT INFORMATION SECTION

PAGE 1

☐ CHANGES

BUSINESS NAME	QUICK TRIP DIESEL PUMP ADDITION		
ADDRESS	1001 SW BLUE PKWY, LEES SUMMIT, MO 64063		
OWNER/OPERATOR NAME	DOUBLE CHECK COMPANY:	TELEPHONE	<NO PRIMARY PHONE>
ADDRESS	4000 RAYTOWN RD. KANSAS CITY, MO 64129 Primary: <NO PRIMARY PHONE> Cell: <NO CELL PHONE>		

EMERGENCY CONTACT INFORMATION

NAME	TELEPHONE
1.	
2.	
3.	
4.	

LOSS REDUCTION TYPE

<input type="checkbox"/> Occupancy	<input type="checkbox"/> Semi-Annual	<input type="checkbox"/> Annual	<input type="checkbox"/> Life Safety	<input type="checkbox"/> Sprinkler	<input type="checkbox"/> Hazardous Material Permit
<input type="checkbox"/> Complaint	<input type="checkbox"/> Explosive Storage	<input type="checkbox"/> UST	<input type="checkbox"/> Post-Incident	<input type="checkbox"/> Open Burning	<input checked="" type="checkbox"/> Other
CLASS: M	Map#: 195E	PFA#:	KNOX BOX:	KNOX LOCATION:	PERMIT # PRCOM20120281

LOSS REDUCTION NARRATIVE

☐ NO VIOLATIONS NOTED

☐ ALL VIOLATIONS RESOLVED

Last Inspection 1st Inspection 2/28/12 2nd Inspection 3rd Inspection 4th Inspection

INSPECTION	INSPECTOR	OUTCOME	DATE
DATE OF REPORT	INSPECTOR	PREVENTION FOLLOW-UP REQUIRED?	RESPONSIBLE SIGNATURE
July 13, 2012	Joe Dir	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	

fuel line pressure test for a diesel fuel pump addition, the test started and ended with 40 psi on the system after a 1-hour test period. normal operating pressure for the system is 30-35 psi