

CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX:

816-969-1201

Inspection Summary

Permit #: PRCOM20120184, Building Permit - Commercial

Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Rated Assembly John Borns Partial Monday, July 16, 2012

Inspection

Partial Correction

1 MISC ALL DESIGNATED SMOKE WALLS FOUND TO BE SCREWED AT

8"/12" PATTERN SIMILAR TO THAT AT DESIGNATED FIRE

WALLS.

Partial Correction

2 MISC OK TO TAPE, MUD & FIRE SEAL FIRE-RATED WALLS AT

FOLLOWING LOCATIONS: CORRIDOR 140 EAST WALL NORTH OF CC.4/1.5; 138 N WALL; 139 S&W WALLS; 122 BOTH FACES;

ON (6.0) FROM (CC.3) TO (DD) SOUTH FACE

Partial Correction

3 MISC OK TO COVER WHEN READY COMPONENTS OF TYPE "F" 2HR

RATED WALL ASSEMBLY: 2ND FLR AHU EAST & SOUTH WALLS

FRAMING, SHAFT LINER + ONE LAYER 5/8" TYPE X GWB;

In-wall Inspection John Borns Partial Monday, July 16, 2012

Partial Correction

1 MISC OK TO COVER WHEN READY GWB WALLS FULL HEIGHT @

FOLLOWING LOCATIONS: AHU RM 147 NE CORNER FOR MOUNTING OF DP-E1-28-HA; 126 & 127 FOR EQUIPMENT INSTALL; TEMPORARY EGRESS CORRIDOR @ 117; INFILL BELOW WINDOWS ALONG (DD) FROM (3.8) TO (5.1); BEHIND HVAC WALL CHASE @ 136 & 138; 119B; 119C; 120; 121; 123; 123A; 123B; 123C; 123D; 123E; 124; 125; 129; 130; 131; 132; 134;

135; BULKHEAD ABOVE DOOR 140; FOR CABLE TRAY @ PART OF CORR 143; WALL PLANE ON (7) FROM (BB.9) TO (DD); 101 FROM (A) TO (CC.3); 118; 119; 119D; 119E; 119F; ON (DD) FROM (3.7) TO (7); 142 W WALL; ON (3) FROM (A) TO (B) CORR 143 S WALL; 136; 137; 138; 139; 140; 141; 143; 144; 145; 146; 147; 149 S,E,W WALLS; 142 ALL WALLS; MODIFICATIONS @ 136 N & 138 S; 101 SOUTH WALL; 153 PLAN EAST WALL; UTILITY CHASES AT 100 SW & 102 NE; 119A S WALL; 122; 147 W WALL; CHASE @ (B)/(1)

Comments: