



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110083, Building Permit - Commercial
Address: 621 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Monday, July 16, 2012

Partial Correction
1 MISC

OK TO COVER WHEN READY CEILING FRAMING +
ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES:
DRIVE-THROUGH CANOPY;

Gas Piping Inspection - Commercial	John Borns	Partial	Monday, July 16, 2012
---	------------	---------	-----------------------

Corrective Action Required

1 MISC

EXPOSED PIPING TO BE PAINTED BEFORE FINAL INSPECTION

Corrective Action Required

2 MISC

ADD SUPPORTS AT TEE-OFF'S TO TWO RTU'S

Gas Service Inspection - Commercial	John Borns	Passed	Monday, July 16, 2012
--	------------	--------	-----------------------

Comments: