



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20120184, Building Permit - Commercial
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Thursday, July 19, 2012

Partial Correction
1 MISC

ALL DESIGNATED SMOKE WALLS FOUND TO BE SCREWED AT 8"/12" PATTERN SIMILAR TO THAT AT DESIGNATED FIRE WALLS.

Partial Correction
2 MISC

OK TO TAPE, MUD & FIRE SEAL FIRE-RATED WALLS AT FOLLOWING LOCATIONS: CORRIDOR 140 EAST WALL NORTH OF CC.4/1.5; 138 N WALL; 139 S&W WALLS; 122 BOTH FACES; ON (6.0) FROM (CC.3) TO (DD) SOUTH FACE; 119A S WALL;

Partial Correction
3 MISC

OK TO COVER WHEN READY COMPONENTS OF TYPE "F" 2HR RATED WALL ASSEMBLY: 2ND FLR AHU EAST & SOUTH WALLS FRAMING, SHAFT LINER + ONE LAYER 5/8" TYPE X GWB;

Comments: