



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20120827, Building Permit - Commercial  
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Partial	Friday, July 20, 2012

Partial Correction  
1 MISC

AT STUDS ACTING IN TENSION SCREW FLANGE-TO-FLANGE CONNECTIONS AT BOTH FLANGES: OK TO COVER WHEN READY ALL CLOUD SOFFITS EXCEPT SE 4' AT SOUTH SERVERY WHERE FOUR TENSION STUDS ARE NOT SECURED TO STRUCTURE ABOVE

Corrective Action Required  
2 MISC

ACT TILE AREAS OK TO COVER EXCEPT  
- AT NORTH SERVERY: 1) TWO LARGE CAN LIGHTS REQUIRE SLACK WIRES 2) FOUR LOCATIONS WITH OPEN BOXES WITH TRANSFORMERS YET TO BE INSTALLED 3) ONE OPEN BOX WHERE POWER POLE TO BE INSTALLED 4) ONE EXISTING ELECT RECEPT AT E WALL TO BE REMOVED OR PROPERLY CLOSED  
- AT SOUTH SERVERY: 1) TWO LARGE CAN LIGHTS REQUIRE SLACK WIRES 2) THREE LOCATIONS WITH OPEN BOXES WITH TRANSFORMERS YET TO BE INSTALLED

**Comments:**