



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20112705, Building Permit - Commercial  
Address: 1201 SW 3RD ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	Mark Harding	Failed	Friday, July 20, 2012

Corrective Action Required  
1 MISC

SOUTH LIGHT POLE BASE-  
FAILED - PROVIDE PROPER DEPTH- AND CLEARANCE AROUND  
CAGE.  
CLEAN OUT PIER HOLE OF LOOSE MATERIAL.

**Comments:**