



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121047, Building Permit - Commercial
Address: 1720 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Partial	Wednesday, July 25, 2012

Partial Correction
1 MISC

PRESSURE TEST HELD STEADY ON GAS PIPING AT COOKING
AREA AND TO EXISTING RTU

In-wall Inspection	John Borns	Passed	Wednesday, July 25, 2012
---------------------------	------------	--------	--------------------------

**Comments: AFTER SHIELD PLATES/BOCA PLATES ARE IN PLACE PER IRC AND IBC
OK TO COVER WHEN READY.**