



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20120415, Building Permit - Commercial
Address: 2401 NE DOUGLAS ST, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Not Ready	Tuesday, July 31, 2012

Corrective Action Required
1 MISC

-FIRE DEPT APPROVAL REQUIRED. DEFICIENCIES ON
SEPARATE LIST
-PLANNING DEPT APPROVAL FOR ACCESSIBLE PARKING
SPACE

IN ADDITION, CORRECT THE FOLLOWING:
-SECURE ALL THE MC CABLES PER CODE ABOVE BOTH
BOOTHES

*DO NOT USE THE EAST SPRAY BOOTH

Comments: