CITY OF LEE'S SUMMIT

CODES ADMINISTRATION DEPARTMENT
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200
Fax (816) 969-1201

PLAN REVIEW CONDITIONS

August 06, 2012

TURNER CONSTRUCTION CO 2345 GRAND BOULEVARD SUITE 1000 KANSAS CITY, MO 64108

Permit No: PRCOM20121257

Project Title: SAINT LUKES EAST 4TH FLOOR SURGICAL ICU
Project Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

Parcel Number: 52400043900000000

Location: SAINT LUKE'S HOSPITAL OF LEE'S SUMMIT LOT 1---LOT 1 (EX PT IN RD)

Type of Work: NEW TENANT FINISH

Occupancy Group: INSTITTIONAL, INCAPACITATED

Description: TENANT FINISH FOR INTENSIVE CARE UNIT

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200 Fire Department (816) 969-1300

Building Plan Review Reviewed By: Michael Weisenborn Approved

Fire Plan Review Reviewed By: Jim Eden Approved

2. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Provide shop drawings for review and approval.

3. 2006 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Provide shop drawings for review and approval.

hydrant systems, fire standpipe systems, fire pump system systems and appurtenances thereto shall be subject to acceas approved by the fire code official. The fire code official The fire code official shall be notified 48 hours before an	eptance tests as contained in the installation standards and al shall be notified before any required acceptance testing.
Action required: Call (816) 969-1300 to schedule testing.	
6. Access controlled doors to the floor shall release with t	he activation of the fire alarm.
Verified at inspection.	
 3006.4 Medical gas systems. Medical gas systems including, but not limited to, distributed regulators and relief devices and valves, shall comply with 	
Action required: Provide documentation of pipe testing. A NFPA 99. Verified at inspection.	All piping and valves shall be labeled in accordance with
X Approved to issue per the listed conditions.	
Do not issue per the listed conditions.	listed conditions
Approved to construct foundation only per the Requires Final Development Plan approval price	
The applicant agrees to incorporate the aforementioned recodes and Ordinances.	equirements into the project to conform to applicable City
	<u>8/6/12</u>
Signature of Applicant	Date
	<u>Turner Construction</u>
Print Applicant Name	CompanyName

5. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.