



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110083, Building Permit - Commercial
Address: 621 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Failed	Tuesday, August 07, 2012

Corrective Action Required
1 MISC

RESOLVE ANY ISSUES FROM OTHER DEPARTMENTS:
- FIRE
- WATER UTILITIES
- PUBLIC WORKS
- PLANNING & DEVELOPMENT

Corrective Action Required
2 MISC

ENSURE ALL WALL PENETRATIONS ARE FULLY SEALED

Corrective Action Required
3 MISC

SECURE TO WALL THE COPPER WATER PIPE AT S SIDE OF
ROLLING STEEL DOOR @ SW

Corrective Action Required
4 MISC

LABEL MAIN DISTRIBUTION PANEL

Corrective Action Required
5 MISC

WATER HOSE CONNECTION BELOW ROOF HATCH REQUIRES
VACUUM BREAKER

Corrective Action Required
6 MISC

PAINTING OF ROOFTOP GAS PIPING: REQUIRES FULL
COVERAGE FULL LENGTH TO CONNECTION AT RTU

Comments: OK TO FIXTURE, STOCK, AND SET UP FOR BUSINESS. NO PUBLIC OR CUSTOMERS PRIOR TO APPROVAL.