



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRRES20121444, Building Permit - Residential  
Address: 713 NW BLACK TWIG LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	John Borns	Failed	Wednesday, August 08, 2012

Corrective Action Required  
1 MISC

OK TO COVER FOLLOWING WALLS/CEILINGS: SHOWER WALLS ONLY AT BATHROOM

Corrective Action Required  
2 MISC

STRUCTURE AND OTHER SYSTEMS AT GARAGE AND CRAWL SPACE TO SUBJECT TO APPROVAL WHEN ACCESSIBLE AT OR BEFORE FINAL INSPECTION. NOTED THAT EXISTING OPEN ELECTRICAL SPLICES AT ATTIC HAVE BEEN ENCLOSED IN NEW JUNCTION BOXES.

Corrective Action Required  
3 MISC

ISOLATE NEUTRAL AND EQUIPMENT GROUND WIRE TERMINATIONS AT ELECTRICAL PANEL

Corrective Action Required  
4 MISC

SECURE NM ELECTRICAL CABLE TO STRUCTURE AT MAX 4.5' INTERVALS

Corrective Action Required  
5 MISC

IRC E3702 PROTECTION OF NM ELECT CABLE BORED THROUGH FRAMING WITH EDGE OF HOLE <1-1/4" FROM FACE OF STUD/PLATE: INSTALL MINIMUM 1/16" THICK HARDENED STEEL SHIELD PLATES TO PROTECT NON-METALLIC CABLE. CHECK ALL

Corrective Action Required  
6 MISC

IRC R502.13; R602.8: FIRE-BLOCK ALL LEVEL-TO-LEVEL OPENINGS. ANY HOLES OR DISCONTINUITIES IN TOP &

Corrective Action Required  
7 MISC

BOTTOM PLATES, HOLES IN FLOOR INCLUDING AT TUB,  
SHOWER, ETC

ALL SYSTEMS ROUGH-IN AT BATHROOM IN PROGRESS.  
SUBJECT TO APPROVAL WHEN COMPLETED. SHOWER WALLS  
OK TO COVER.

**Comments:**