



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRRES20121444, Building Permit - Residential  
Address: 713 NW BLACK TWIG LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	John Borns	Partial	Thursday, August 09, 2012

### Partial Correction

1	MISC
Corrective Action Required	
2	MISC

OK TO COVER WALLS & CEILINGS EXCEPT AT GARAGE

STRUCTURE AND OTHER SYSTEMS AT GARAGE AND CRAWL SPACE TO SUBJECT TO APPROVAL WHEN ACCESSIBLE AT OR BEFORE FINAL INSPECTION. NOTED THAT EXISTING OPEN ELECTRICAL SPLICES AT ATTIC HAVE BEEN ENCLOSED IN NEW JUNCTION BOXES.

### Comments: