

CITY OF LEE'S SUMMIT

CODES ADMINISTRATION DEPARTMENT

220 SE Green Street

Lee's Summit, MO 64063

(816) 969-1200

Fax (816) 969-1201

PLAN REVIEW CONDITIONS

August 10, 2012

CMG CONSTRUCTION
8336 NIEMAN RD
LENEXA, KS 66214

Permit No: PRCOM20121747
Project Title: COLLIERS INTERNATIONAL
Project Address: 1131 NE RICE RD, LEES SUMMIT, MO 64086
Parcel Number: 52810032100000000
Location: MINOR SUB OF TR A, REPLAT OF LOT 2 DEERBROOK COMMERCIAL PARK LOT 5
Type of Work: ALTERATION COMMERCIAL
Occupancy Group: UNCLASSIFIED
Description: WHITE BOX FINISH

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Michael Weisenborn

Rejected

1. No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section. Expert from Sec. 7-130, Lees Summit Code of Ordinances.

Action required - Our records show that Quality Plumbing has not renewed their business license for the 2012-2013 fiscal year. Their business license needs to be renewed prior to permit issuance.

2. The door shown in the corridor to the storage area does not meet accessible egress requirements from the pull side.

Action required - Per conversations with the contractor the door is to be removed from the project.

3. 2006 IBC 1210.1 - Floors. In other than dwelling units, toilet and bathing room floors shall have a smooth, hard, nonabsorbent surface that extends upward onto the walls at least 6 inches.

Action required - This will be verified on inspection.

4. 2006 IBC 1210.2 - Walls. Walls within 2 feet of urinals and water closets shall have a smooth, hard, nonabsorbent surface, to a height of 4 feet above the floor, and except for structural elements, the materials used in such walls shall be of a type that is not adversely affected by moisture. Exceptions: 1. Dwelling units and sleeping

units. 2. Toilet rooms that are not accessible to the public and which have not more than one water closet. Accessories such as grab bars, towel bars, paper dispensers and soap dishes, provided on or within walls, shall be installed and sealed to protect structural elements from moisture.

Action required - This will be verified on inspection.

5. The plans show a mop sink being added in the men's restroom that will interfere with required clear spaces for accessibility.

Action required - The mop sink needs to be relocated.

6. The plans do not provide any information for the construction and bracing of the new wall separating the main area and the storage area.

Action required - Provide additional information.

7. This permit is for the construction of a "white box" space only and does not allow for the occupancy of the space. A separate permit will be required for the future tenant to verify that they meet all occupancy type requirements.

Action required - This comment is for information purposes.

Fire Plan Review

Reviewed By: Brian Austerman

Approved

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Action Required: Provide plans for approval for any sprinkler modifications

2. 2006 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Action Required: Provide plans for approval for any alarm system modifications

3. 2006 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Action Required: Provide a minimum size of 2A10B:C extinguishers. Verified at inspection

4. 2006 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

Action Required: Address all exterior doors leading into the space, verified at inspection

5. 2006 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

Action Required: Sprinkler system must have current certification at time of final

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.