



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20114952, Building Permit - Commercial
Address: 203 SW JEFFERSON ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Borns	Partial	Monday, August 13, 2012

Corrective Action Required
7 MISC

ELECT RECEPT @ NORTH END OF KIT COUNTER NOT GFI-PROTECTED.

Corrective Action Required
8 MISC

ELECT RECEPT NEAR SINK AT 1ST FLR RESTROOM NOT GFI PROTECTED

Corrective Action Required
13 MISC

ELECT RECEPT @ EXTERIOR WALL WEST NOT GFI-PROTECTED. IN-USE COVER REQUIRED FOR WET LOCATION.

Comments: OK FOR TEMPORARY USE AND OCCUPANCY THROUGH 8/20/2012