



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20120184, Building Permit - Commercial  
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Tuesday, August 14, 2012

Partial Correction  
1 MISC

ALL DESIGNATED SMOKE WALLS FOUND TO BE SCREWED AT 8"/12" PATTERN SIMILAR TO THAT AT DESIGNATED FIRE WALLS.

Partial Correction  
2 MISC

OK TO TAPE, MUD & FIRE SEAL FIRE-RATED WALLS AT FOLLOWING LOCATIONS: CORRIDOR 140 EAST WALL NORTH OF CC.4/1.5; 138 N WALL; 139 S&W WALLS; 122 BOTH FACES; ON (6.0) FROM (CC.3) TO (DD) SOUTH FACE; 119A S WALL; ELEVATOR CLOSET SIDE & FRONT WALLS ONE LAYER BOTH FACES 5/8" TYPE X GWB; GAS ROOM EAST WALL ONE LAYER BOTH FACES 5/8" TYPE X GWB

Partial Correction  
3 MISC

OK TO COVER WHEN READY COMPONENTS OF TYPE "F" 2HR RATED WALL ASSEMBLY: 2ND FLR AHU EAST & SOUTH WALLS FRAMING, SHAFT LINER + TWO LAYERS 5/8" TYPE X GWB; ELEVATOR CLOSET WALL AT UTILITY CHASE SHAFT LINER + ONE LAYER 5/8" TYPE X GWB; GAS ROOM SOUTH WALL SHAFT LINER + ONE LAYER 5/8" TYPE X GWB

**Comments:**