



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20114952, Building Permit - Commercial
Address: 203 SW JEFFERSON ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Borns	Partial	Wednesday, August 15, 2012

Corrective Action Required
4 MISC

OBTAIN FINAL APPROVAL OF WATER DEPARTMENT

Comments: PLEASE ASK BEN HASKAMP (816-969-1930) FROM WATER UTILITIES DEPT TO INFORM ME WHEN BACKFLOW DEVICE AT WATER SERVICE ENTRY IS APPROVED, WHEREUPON I WILL ISSUE FINAL APPROVAL AND CLOSE PERMIT. OK TO SET UP FOR BUSINESS IN MEANTIME.