## **CITY OF LEE'S SUMMIT**

CODES ADMINISTRATION DEPARTMENT 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 Fax (816) 969-1201

## PLAN REVIEW CONDITIONS

August 17, 2012

ROYAL SEAL CONSTRUCTION INC 124 MCMAKIN ROAD BARTONVILLE, TX 76226

Permit No:	PRCOM20121448
Project Title:	WHITE HOUSE BLACK MARKET
Project Address:	860 NW BLUE PKWY, Unit:S, LEES SUMMIT, MO 64086
Parcel Number:	5170003330000000
Location:	SUMMIT FAIR LOTS 22A & 24ALOT 22A
Type of Work:	NEW TENANT FINISH
Occupancy Group:	MERCANTILE
Description:	NEW TENANT FINISH

## The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review Reviewed By: Michael Weisenborn Approved

1. Lee's Summit Code of Ordinance, Section7-130.10 - Business License. It shall be unlawfull for any person to engage in the construction contracting business without first obtaining a business license as required under the applicable provisions of Chapter 28 of the Lee's Summit Code of Ordinances.

Action required - Provide the name of the general contractor prior to permit approval. A minimum a Lee's Summit General Contractor Class "B" license is required.

2. No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section. Expert from Sec. 7-130, Lees Summit Code of Ordinances.

Action required - Provide the names of the mechanical, electrical and plumbing subcontractors prior to permit approval.

5. 2006 IBC 1006.3 - Illumination emergency power. The power supply for means of egress illumination shall normally be provided by the premises electrical supply. In the event of power supply failure, an emergency electrical system shall automatically illuminate the following areas.

1. Aisles and unenclosed egress stairways in rooms and spaces that require two or more means of egress.

2. Corridors, exit enclosures and exit passageways in building required to have two or more exits.

3. Exterior egress components at other than the level of exit discharge until exit discharge is accomplished for buildings required to have two or more exits.

4. Interior exit discharge elements, as permitted in Section 1024.1, in buildings required to have two or more exits.

5. Exterior landings, as required by Section 1008.1.5, for exit discharge doorways in building required to have two or more exits.

The emergency power system shall provide power for a duration of not less than 90 minutes and shall consist of storage batteries, unit equipment or an on-site generator. The installation of the emergency power system shall be in accordance with Section 2702.

Action required - Show how emergency lighting on the exerior of the building at the egress doors will be met.

Mike Weisenborn 07/30/2012 4:39 PM -- To be verified at inspection.

6. The bottom chord braces at the rtu(s) shall be welded once the units have been installed. This will need to be verified by the city inspection staff.

Action required - This comment is for information purposes.

## Fire Plan ReviewReviewed By: Jim EdenApproved

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Provide shop drawings for review and approval.

2. 2006 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Provide shop drawings for review and approval.

3. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule alarm tests.

4. 2006 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

The address shall be placed on/over the front and rear doors unless already provided. Verified inspection.

5. All egress doors shall be equiped with thumb latches or panic hardware. Verified at inspection.

- \_\_\_\_\_ Approved to issue per the listed conditions.
- \_\_\_\_\_ Do not issue per the listed conditions.
- \_\_\_\_\_ Approved to construct foundation only per the listed conditions.
- \_\_\_\_\_ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

Signature of Applicant	Date	
Print Applicant Name	CompanyName	

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.