

CITY OF LEE'S SUMMIT

CODES ADMINISTRATION DEPARTMENT

220 SE Green Street

Lee's Summit, MO 64063

(816) 969-1200

Fax (816) 969-1201

PLAN REVIEW CONDITIONS

August 17, 2012

ROYAL SEAL CONSTRUCTION INC
124 MCMAKIN ROAD
BARTONVILLE, TX 76226

Permit No: PRCOM20121462
Project Title: CHICO'S
Project Address: 860 NW BLUE PKWY, Unit:H, LEES SUMMIT, MO 64086
Parcel Number: 51700033300000000
Location: SUMMIT FAIR LOTS 22A & 24A---LOT 22A
Type of Work: NEW TENANT FINISH
Occupancy Group: MERCANTILE
Description: NEW TENANT FINISH

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Michael Weisenborn

Approved

1. Lee's Summit Code of Ordinance, Section 7-130.10 - Business License. It shall be unlawful for any person to engage in the construction contracting business without first obtaining a business license as required under the applicable provisions of Chapter 28 of the Lee's Summit Code of Ordinances.

Action required - Provide the name of the licensed general contractor for this project prior to permit approval. A minimum of a Class B license is required.

2. No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section. Except from Sec. 7-130, Lees Summit Code of Ordinances.

Action required - Provide the name of licensed mechanical, electrical and plumbing contractors for this project prior to permit approval.

6. Codes Administration - The bottom chord braces at the rtu(s) shall be welded once the units have been installed. This will need to be verified by the city inspection staff.

Action required - This comment is for information purposes.

Fire Plan Review**Reviewed By: Brian Austerman****Approved**

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Provide shop drawings for review and approval.

ACKNOWLEDGED IN RESUB

2. 2006 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Provide shop drawings for review and approval.

ACKNOWLEDGED IN RESUB

4. 1006.3 Illumination emergency power.

The power supply for means of egress illumination shall normally be provided by the premises' electrical supply. In the event of power supply failure, an emergency electrical system shall automatically illuminate the following areas:

1. Aisles and unenclosed egress stairways in rooms and spaces that require two or more means of egress.
2. Corridors, exit enclosures and exit passageways in buildings required to have two or more exits.
3. Exterior egress components at other than the level of exit discharge until exit discharge is accomplished for buildings required to have two or more exits.
4. Interior exit discharge elements, as permitted in Section 1024.1, in buildings required to have two or more exits.
5. Exterior landings, as required by Section 1008.1.5, for exit discharge doorways in buildings required to have two or more exits.

The emergency power system shall provide power for a duration of not less than 90 minutes and shall consist of storage batteries, unit equipment or an on-site generator. The installation of the emergency power system shall be in accordance with Section 2702 of the International Building Code.

Action required: Provide exterior emergency lighting.

RESOLVED ON RESUB

- _____ Approved to issue per the listed conditions.
- _____ Do not issue per the listed conditions.
- _____ Approved to construct foundation only per the listed conditions.
- _____ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

Signature of Applicant

Date

Print Applicant Name

CompanyName

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.