

July 26th, 2012

Mike Weisenborn City of Lee's Summit Codes Administration Department 220 SE Green St. Lee's Summit, MO 64063

RE:

PRCOM20121142
EAGLE CREEK CHURCH
1499 SW MARKET ST, LEES SUMMIT, MO 64081

Dear Mr. Weisenborn

The wall separating Worship Hall 108 and Reading Room 118 was designed with two layers of gypsum board on both sides for acoustic reasons only. This wall may be constructed with one layer of 5/8" gypsum board on both sides. Floor plan note #5 on sheet A2 shall be revised to indicate only one layer of 5/8" gypsum board is required on each side.

Should you have any questions regarding this correspondence, please do not hesitate to contact our office.

Sincerely,

GUY GRONBERG ARCHITECTS, P.C.

Ken Kleffner