



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20121747, Building Permit - Commercial  
Address: 1131 NE RICE RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Partial	Wednesday, August 22, 2012

### Partial Correction

1	MISC	OK TO PLACE ACT BORDERS (2' MAXIMUM) AT MAIN AREA (STORAGE ROOM NOT READY)
Corrective Action Required		
2	MISC	REMOVE ABANDONED ROD & STRAP HANGERS
Corrective Action Required		
3	MISC	COMPLETE HVAC SUPPLY & RETURN SYSTEM PER SMACNA. CONNECT FLEX CONNECTORS WITH INNER LAYER SECURED AND OUTER LAYER SECURED. ELIMINATE EXCESS CONNECTOR LENGTH. SEAL ALL ABANDONED OPENINGS. SET AND CONNECT ALL DIFFUSERS AND GRILLES. ELIMINATE ABANDONED EXHAUST PATH(S) TO ATMOSPHERE.
Corrective Action Required		
4	MISC	ADJUST FIRE PROTECTION SPRINKLER DROPS TO GRID ELEVATION.

<b>In-wall Inspection</b>	John Borns	Passed	Wednesday, August 22, 2012
---------------------------	------------	--------	----------------------------

**Comments:**