



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121823, Building Permit - Commercial
Address: 620 NW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Wednesday, August 22, 2012

Partial Correction
1 MISC

OK TO COVER WHEN READY BURIED CONDUIT AND BOXES AT
FOLLOWING LOCATIONS: BRANCH TO SHELTER LOCATION; 2"
PVC FROM CONTROL BOX AT N TO 200' TO SOUTH;

Comments: