



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20121257, Building Permit - Commercial  
Address: 110 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	John Borns	Partial	Thursday, August 23, 2012

Partial Correction

1 MISC

OK TO COVER WHEN READY WALL TOP-OUT AT FOLLOWING LOCATIONS: FROM D.1/5.7 TO H.6/5.7 TO H.6/6; H.2/6.5 TO F.9/6.6 TO H.6/6.8 TO H.9/6.7;

Partial Correction

2 MISC

OK TO COVER WHEN READY EXTERIOR PERIMETER WALLS FROM BLDG "A" @ D.5/9 TO EE/2 TO O/9 TO K/3 TO G/4 TO E/0; ALONG SE EXTERIOR WALL; ALONG S EXTERIOR WALL TO BLDG "A"

**Comments:**