



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20120184, Building Permit - Commercial
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Thursday, August 23, 2012

Corrective Action Required
1 MISC

RESOLVE ANY ISSUES WITH OTHER DEPARTMENTS:

- FIRE
- PUBLIC WORKS
- WATER
- PLANNING AND DEVELOPMENT

OK TO SET UP FOR BUSINESS OPERATION; NO PUBLIC NOR PATIENTS PRIOR TO APPROVAL

Corrective Action Required
2 MISC

OBTAIN FINAL CERTIFICATION OF LIGHTNING PROTECTION SYSTEM

Corrective Action Required
3 MISC

PROVIDE WITNESS CERTIFICATION OF GENERATOR TEST OF EMERGENCY ELECTRICAL SYSTEM

Corrective Action Required
4 MISC

SPACES NOT READY FOR FINAL INSPECTION:

- AHU
- OR#4
- 145 (PLUMBING WORK IN PROGRESS)

Corrective Action Required
5 MISC

INSTALL WIRE GUARDS OVER UNPROTECTED LUMINAIRES AT SERVER ROOM, STERIS EQUIPMENT ACCESS SPACE

**Occupancy
Inspection - Fire**

Joe Dir

Temporary C of O

Thursday, August 23, 2012

Corrective Action Required

1 MISC

- uncover all sprinkler heads throughout phased areas
- label sprinkler system valves in stairway, 1st and 2nd floors
- permanent room labeling
- med-gas line certification test
- label all med-gas valving as to area served
- test all exit lights room/corridor lighting, outlets with generator power
- test the 1st floor stairway flow alarm

Comments: