

CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX:

816-969-1201

Inspection Summary

Permit #: PRRES20110739, Building Permit - Residential Address: 101 SW VIEW HIGH DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Inspector: Date:

Pool Final -Mark Harding Failed Friday, August 24, 2012

Residential

Corrective Action Required

E4103.1.1 Location POOL EQUIPMENT LOCATION AND CLEARANCES.

> PROVIDE 15-20 AMP OUTLET WITHIN 20FT OF POOL (GFCI) 2. PROVIDE GAS PRESSURE TEST ON GAS LINE INSTALLED TO

POOL HEATER.

NO INSPECTION ON GAS LINE.

POOL HEATER WAS NOT ADDED TO PERMIT. CHECK ELECTRICAL WHERE TIES INTO HOUSE.

Corrective Action Required

MISC 2PM TO MEET CONTRACTOR

WAITED 25MINUTES

RECALL WHEN PRESENT

Comments: