



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121047, Building Permit - Commercial
Address: 1720 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	John Borns	Partial	Friday, August 24, 2012

Partial Correction
1 MISC

NO ISSUES FOUND ON LIGHT TEST OF GREASE DUCT AT BOTH HOODS. OK TO COVER WITH 1ST LAYER OF DUCT WRAP WHEN READY.

Partial Correction
2 MISC

1ST LAYER OF DUCT WRAP OK TO COVER WHEN READY

Comments: