



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20112705, Building Permit - Commercial
Address: 1201 SW 3RD ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Planning	Christina Stanton	Temporary C of O	Monday, August 27, 2012

Corrective Action Required
1

Handicapped Accessible Sign. The correct sign is noted on details #10 and #17 of Sheet C8.0. Correct prior to Final Occupancy.

Corrective Action Required
2

Lighting. The lighting levels shall be verified by the Director of Planning & Development prior to Final Occupancy.

Occupancy Inspection - Planning	Christina Stanton	Temporary C of O	Monday, August 27, 2012
--	----------------------	------------------	-------------------------

Corrective Action Required
1 MISC

Handicapped Accessible Sign. The correct sign is noted on details #10 and #17 of Sheet C8.0. Correct prior to Final Occupancy.

Corrective Action Required
2 MISC

Lighting. The lighting levels shall be verified by the Director of Planning & Development prior to Final Occupancy.

Comments: Planning - ok for tco for TCO 10Days