



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121405, Building Permit - Commercial
Address: 178 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	John Borns	Partial	Tuesday, August 28, 2012

Partial Correction
1 MISC

UNDER-SLAB ELECTRICAL CONDUIT MATERIAL &
WORKMANSHIP: OK TO COVER WHEN READY FROM NORTH
WALL TO WITHIN 20' OF MDP

Comments: