



**CITY OF LEE'S SUMMIT**  
**CODES ADMINISTRATION**  
220 SE GREEN ST.  
P.O.BOX 1600

**PHONE:**  
816-969-1200

**FAX:**  
816-969-1201

# Temporary Certificate of Occupancy

---

**Permit #:** PRCOM20120184  
**Address:** 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086  
**Inspected On:** Wednesday, August 29, 2012  
**Inspected By:** John Borns  
**Expiration Date:** 10/18/2012 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Temporary C of O	Wednesday, August 29, 2012

**Corrective Action Required:**

1 MISC RESOLVE ANY ISSUES WITH FIRE DEPARTMENT

**Corrective Action Required:**

2 MISC PROVIDE CERTIFICATION OF LIGHTNING PROTECTION SYSTEM

**Corrective Action Required:**

3 MISC SPACES NOT READY FOR FINAL INSPECTION:  
- AHU  
- OR#4  
- ROOFTOPS

**Corrective Action Required:**

5 MISC ROOFTOPS:  
- COMPLETE RTU ENCLOSURES  
- ELECT RECEPES MUST HAVE IN-USE COVERS  
- VERIFY ELECT RECEPES WITHIN 10m OF RTU'S

- CHECK RE OPEN JOINT UNDER STONE COPING
- FINAL CLEANUP
- LOW ROOF NOT READY FOR INSP PER JASON

**Comments:**