



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRRES20121059, Building Permit - Residential
Address: 1502 NE HARDAGE CIR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sewer Service Inspection - Residential	Khanh Nguyen	Passed	Wednesday, August 29, 2012

Comments:

PRESSURE SEWER SYSTEM-APPROVED

*ONCE THE LOW PRESSURE SEWER SYSTEM IS CONNECTED AND FUNCTIONAL, THE EXISTING SEPTIC TANK SHALL HAVE THE CONTENT PUMPED OUT BY A LICENSED PUMPING COMPANY. A RECEIPT FOR PUMPING SHALL BE PROVIDED TO THE CODE DEPARTMENT TO RETAIN WITH THE PERMIT RECORD. THE SEPTIC TANK SHALL BE COLLAPSED OR FILLED