



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20121479, Building Permit - Commercial

Address: 120 NE SAINT LUKES BLVD, Unit:200, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	Khanh Nguyen	Partial	Thursday, August 30, 2012

Corrective Action Required  
1 MISC

THE FOLLOWINGS ARE INSPECTED:  
-WALL FRAMING IN CORRIDORS 2E143, E45

**Comments:**