

CITY OF LEE'S SUMMIT

CODES ADMINISTRATION DEPARTMENT

220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200
Fax (816) 969-1201

PLAN REVIEW CONDITIONS

September 10, 2012

LEE'S SUMMIT R-7 SCHOOL DISTRICT
502 SE TRANSPORT DRIVE
LEE'S SUMMIT, MO 64081

Permit No: PRCOM20122020
Project Title: LSHS ROBOTIC
Project Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063
Parcel Number: 61510026300000000
Location: MUCKEY ADD PT OF LOT 1 & PT N 1/2 SEC 08-47-31 DAF; BEG AT SW COR SD LOT 1 TH N 220' TH E 88.5' TH N 65' MOL TH E 88.5' TH S 290' TO SE COR SD LOT 1 TH E 1110' MOL TO WLY ROW LI M-291 HWY TH SLY ALG SD ROW 1070' MOL TH W 435' MOL TH S 510' TO NLY ROW LI BLUE PARKWAY TH W ALG SD ROW 850' MOL TH N 812' MOL TH W 135' MOL TH N 678' MOL TH E 135.77' TH N 95' MOL TO POB
Type of Work: ALTERATION COMMERCIAL
Occupancy Group: EDUCATIONAL
Description: MODIFY/ADD TO ELECTRICAL, FOR ROBOTIC COMPETITION

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Michael Weisenborn

Approved

Fire Plan Review

Reviewed By: Brian Austerman

Approved with Conditions

1. 605.5 Extension cords.

Extension cords and flexible cords shall not be a substitute for permanent wiring. Extension cords and flexible cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances.

For information only

2. 605.5.1 Power supply.

Extension cords shall be plugged directly into an approved receptacle, power tap or multiplug adapter and, except for approved multiplug extension cords, shall serve only one portable appliance.

For information only

3. 605.4.2 Power supply.

Relocatable power taps shall be directly connected to a permanently installed receptacle.

For information only

- _____ Approved to issue per the listed conditions.
- _____ Do not issue per the listed conditions.
- _____ Approved to construct foundation only per the listed conditions.
- _____ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

Signature of Applicant

Date

Print Applicant Name

CompanyName

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.