



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20121010, Building Permit - Commercial  
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	John Borns	Partial	Tuesday, September 11, 2012

Partial Correction  
1 MISC

OK TO COVER WHEN READY EXTERIOR WALL L.G. STEEL FRAMING AT FOLLOWING LOCATIONS (AFTER DISCUSSED MISSING SCREWS ARE DRIVEN IN PLACE): 6TH FLOOR PARAPET FROM D/13.1 TO D/19 TO A/19 TO A/14;

**Comments:**