



**CITY OF LEE'S SUMMIT**  
**CODES ADMINISTRATION**  
220 SE GREEN ST.  
P.O.BOX 1600

**PHONE:**  
816-969-1200

**FAX:**  
816-969-1201

# Temporary Certificate of Occupancy

---

**Permit #:** PRRES20116155  
**Address:** 1721 NE WOODLAND SHORES CT, LEES SUMMIT, MO 64086  
**Inspected On:** Wednesday, September 12, 2012  
**Inspected By:** Khanh Nguyen  
**Expiration Date:** 10/12/2012 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Temporary C of O	Wednesday, September 12, 2012

**Corrective Action Required:**

1 MISC

-OBTAIN LAWN SPRINKLER PERMIT  
-FINAL GRADE, SOD, SPLASHBLOCKS

-INSTALL SECONDARY LOCKING DEVICES FOR BASEMENT  
SLIDE DOORS-PIN ASSY OR BOTTOM-MOUNTED BOLT ASSY

**\*FROM ORDINANCE**

All sliding glass doors shall be equipped with a secondary locking device consisting of a metal pin or a surface mounted bolt assembly. Metal pins shall be installed at the intersection of the inner and outer panels of the inside door and shall not penetrate the frame's exterior surface. The surface mounted bolt assembly shall be installed at the base of the door.

(Ord. No. 6600, § 1, 3-13-2008)

\*THERE IS TOO MUCH PLAY IN THE SLIDE DOOR. HAVE THE DOORS ADJUSTED. THE ORDINANCE REQUIRES THAT THE BOLT ASSY. BE BOTTOM-MOUNTED

**Comments:**