



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121481, Building Permit - Commercial
Address: 120 NE SAINT LUKES BLVD, Unit:220, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Passed	Thursday, September 13, 2012

Comments: OK TO ONE-SIDE TOP-OUT WALL GWB DOWN TO 10' A.F.F. THROUGHOUT.