



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20121791, Building Permit - Commercial  
Address: 28 SE 3RD ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	John Borns	Passed	Friday, September 14, 2012
<b>Rough Electrical Inspection - Commercial</b>	John Borns	Passed	Friday, September 14, 2012

**Comments: WOOD FRAMING FOR WALL INFILL @ TWO LOCATIONS OK TO COVER WHEN READY. HAVE ARCHITECT REVISE DRAWING AND RE-SUBMIT TO CODES PLAN REVIEW FOR RECORD OF INTERIOR PARTITIONS AS ACTUALLY CONSTRUCTED. ELECTRICAL CONDUCTORS NOW PULLED AND GROUND PIGTAILS INSTALLED; OK TO INSTALL DEVICES AND CLOSE BOXES WHEN READY.**