



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20121823, Building Permit - Commercial
Address: 620 NW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Monday, September 17, 2012

Partial Correction
1 MISC

OK TO COVER WHEN READY BURIED CONDUIT AND BOXES AT FOLLOWING LOCATIONS: BRANCH TO SHELTER LOCATION; 2" PVC FROM CONTROL BOX AT NORTH END TO 260' SOUTH [20' N OF EXISTING SIDEWALK]; FROM SIDEWALK TO 110' SOUTH; TO POWER POLE N OR MONUMENT SIGN; FROM J.B. LOCATION S.W. OF SHELTER LOCATION TO J.B. LOCATION 130' N; 3 WAY JUNCTION AT UTILITY POLE N OF ENTRANCE, TWO CONDUIT APPROVED TO MONUMENT; SLEEVE PLACED UNDER SIDEWALK + CONDUIT INSTALLED AND CONNECTED TO N & S RUNS

Comments: